

TABLE 2: NON-RESIDENTIAL WATER USE FACTORS

<u>Group I - Low to Moderate Use</u>				<u>0.00007 AF/SF</u>		
Auto Uses	Retail	Warehouse	Dental/Medical/Veterinary Clinics	Fast Photo		
Church	Nail Salon	Family Grocery	Office	School	Bank	Gym
 <u>Group II – High Use</u>				<u>0.0002 AF/SE</u>		
Bakery	Pizza	Coffee House	Supermarket/Convenience Store			
Dry Cleaner	Deli		Sandwich Shop			
 <u>Group III- Miscellaneous Uses - Each Category is Calculated Separately</u>						
Assisted Living (more than 6 beds) ²				0.085 per bed		
Beauty Shop/Dog Grooming				0.0567 AF/station		
Child Care				0.0072 AF/child		
Dormitory ¹				0.040 AF/room		
Gas Station				0.0913 AF/pump		
Laundromat				0.200 AF/machine		
Meeting Hall				0.00053 AF/sf		
Motel/Hotel/Bed and Breakfast:				0.100 AF/room		
w/Large Bathtub (add to room factor)				0.030 AF/tub		
Irrigated areas not immediately adjacent (i.e. within 10 feet of any building):				ETWU		
Plant Nursery				0.00009 AF/sf total land		
Public Toilets				0.058 AF/toilet		
Public Urinals				0.036 AF/urinal		
Zero Water Consumption Urinal(s)				No value		
Restaurant (General/Bar):				0.020 AF/seat		
Restaurant (24-Hour & Fast Food):				0.038 AF/seat		
Self-Storage				0.0008 AF/storage unit		
Skilled Nursing				0.120 AF/bed		
Spa				0.050 AF/spa		
Swimming Pool				0.020 AF/100 sf surface area		
Theater				0.0012 AF/seat		

Group IV- Modified Non-Residential Uses – Users listed in this category have reduced water Capacity from the types of uses listed in Groups I-III and have received a Water Use Credit for modifications. The General Manager shall maintain a list of specific properties in this Group that have received a Water Use Credit pursuant to Rule 25.5 for permanent reduction in use.

For all new Connections -- Refer to Rule 24-B-2, Exterior Non-Residential Water Demand Calculations.

Note: Any Non-Residential water use which cannot be characterized by one of the use categories set forth in Table 2 shall be designated as “other” and assigned a factor which has a positive correlation to the anticipated Water Use Capacity for that Site.

Note: Unenclosed structures are exempt from the Non-Residential Permit requirements and have no Water Credit value.

¹ Dormitory water use at educational facilities is a Residential use although the factor is shown on Table 2.

² Assisted living Dwelling Units shall be permitted as Residential uses per Table 1, Residential Fixture Unit Count Values

Table amended by Ordinance No. 125 (9/29/2006); Resolution 2008-01 (1/24/2008); Resolution 2010-15 (12/13/2010); Resolution 2013-16 (9/16/13)