

EXHIBIT 26-A

MONTEREY PENINSULA WATER MANAGEMENT DISTRICT
GROUNDWATER QUALITY MONITORING RESULTS
 Carmel Valley Aquifer Sample Collection Date: May 20, 2015
 Units are milligrams per liter unless otherwise noted.

Water Quality Constituent	Specific Conductance (micromhos/cm)	Total Alkalinity (as CaCO3)	pH	Chloride	Sulfate	Ammonia Nitrogen (as NH3)	Nitrate Nitrogen (as NO3)	Total Organic Carbon	Calcium	Sodium	Magnesium	Potassium	Iron	Manganese	Orthophosphate	Total Dissolved Solids	Hardness (as CaCO3)	Boron	Bromide	Fluoride
Drinking Water Standard	900 1600 2200 (2)	NA	NA	250 500 600 (2)	250 500 600 (2)	NA	45	NA	NA	NA	NA	NA	0.3	0.05	NA	NA	NA	NA	NA	NA
Sampling Location																				
<i>Upper Carmel Valley Aquifer</i>																				
16S/2E-33Q1	566	162	7.0	31	71	<0.05	4	1.1	61	31	18	3.1	0.357	0.025	<0.1	343	226	<0.05	0.1	0.3
17S/2E-03La	345	111	7.2	12	36	<0.05	<1	0.9	31	17	10	2.2	<0.010	<0.010	<0.1	206	119	<0.05	<0.1	0.2
17S/2E-10B1	700	182	7.0	44	106	<0.05	7	2.2	72	39	24	3.0	<0.010	<0.010	<0.1	446	279	<0.05	0.1	0.4
<p>(1) Maximum contaminant levels are from California Domestic Water Quality and Monitoring Regulations, Title 22, 1977.</p> <p>(2) The three values listed for certain constituents refer to the "recommended" level, the "upper" level, and "short-term use" level, respectively.</p>																				

MONTEREY PENINSULA WATER MANAGEMENT DISTRICT
GROUNDWATER QUALITY MONITORING RESULTS
 Carmel Valley Aquifer Sample Collection Date: July 2, 2014
 Units are milligrams per liter unless otherwise noted.

Water Quality Constituent	Specific Conductance (micromhos/cm)	Total Alkalinity (as CaCO3)	pH	Chloride	Sulfate	Ammonia Nitrogen (as NH3)	Nitrate Nitrogen (as NO3)	Total Organic Carbon	Calcium	Sodium	Magnesium	Potassium	Iron	Manganese	Orthophosphate	Total Dissolved Solids	Hardness (as CaCO3)	Boron	Bromide	Fluoride
Drinking Water Standard	900 1600 2200 (2)	NA	NA	250 500 600 (2)	250 500 600 (2)	NA	45	NA	NA	NA	NA	NA	0.3	0.05	NA	NA	NA	NA	NA	NA
Sampling Location																				
<i>Upper Carmel Valley Aquifer</i>																				
16S/2E-33Q1	474	149	6.8	25	56	<0.05	0.6	1.06	51	27	17	5.0	9.463	0.859	<0.1	277	197	<0.05	<0.1	0.3
17S/2E-03La	372	126	7.1	14	39	<0.05	<1	0.88	38	20	12	2.5	<0.010	<0.010	<0.1	208	144	<0.05	<0.1	0.2
17S/2E-10B1	448	143	7.0	20	55	<0.05	2	1.28	44	30	14	2.4	<0.010	<0.010	<0.1	274	168	<0.05	<0.1	0.5
<p>(1) Maximum contaminant levels are from California Domestic Water Quality and Monitoring Regulations, Title 22, 1977.</p> <p>(2) The three values listed for certain constituents refer to the "recommended" level, the "upper" level, and "short-term use" level, respectively.</p>																				