

EXHIBIT 26-A

MONTEREY PENINSULA WATER MANAGEMENT DISTRICT

GROUNDWATER-QUALITY MONITORING RESULTS

Carmel Valley Aquifer Sample Collection Date: November 23, 2015
Seaside Basin Sample Collection Dates: July 23, August 4, September 23 and 24, 2015

Units are milligrams per liter unless otherwise noted.

Water Quality Constituent	Specific Conductance (micromhos/cm)	Total Alkalinity (as CaCO ₃)	pH	Chloride	Sulfate	Ammonia Nitrogen (as N)	Nitrate Nitrogen (as NO ₃)	Total Organic Carbon	Calcium	Sodium	Magnesium	Potassium	Iron	Manganese	Orthophosphate	Total Dissolved Solids	Hardness (as CaCO ₃)	Boron	Bromide	Fluoride	
Drinking Water Standard (1)	900 1600 2200 (2)	NA	NA	248 800 800 (2)	200 500 500 (2)	NA	45	NA	NA	NA	NA	NA	0.3	0.05	NA	NA	NA	NA	NA	NA	
Sampling Location	River Mile																				
Carmel Valley Aquifer																					
16S/1W-14Jh (shal)	0.07 no longer in annual sampling network																				
16S/1W-14Jf (inter)	0.07 no longer in annual sampling network																				
16S/1W-14Jg (deep)	0.07 no longer in annual sampling network, destroyed by flooding																				
16S/1W-13Mc (shal)	0.31 no longer in annual sampling network																				
16S/1W-13Mb (inter)	0.31 no longer in annual sampling network																				
16S/1W-13Md (deep)	0.31 no access in November or December due to high water in Lagoon																				
16S/1W-13Lb (shal)	0.65 no longer in annual sampling network																				
16S/1W-13La (inter)	0.65 no longer in annual sampling network																				
16S/1W-13Lc (deep)	0.65	990	200	7.2	100	148	0.67	<1	2.6	84	91	23	3.9	2.509	0.792	0.1	640	304	0.16	0.3	1.3
16S/1E-17J4	3.85	360	68	6.4	19	66	<0.05	1	1.9	30	21	11	3.0	0.972	0.028	<0.1	226	120	<0.05	<0.1	0.3
16S/1E-17R2	3.86	1127	191	6.6	101	240	<0.05	<1	5.2	123	79	28	3.9	6.421	0.267	<0.1	737	422	0.07	0.2	0.2
16S/1E-23E4	6.53	1100	286	7.1	89	160	<0.05	<1	3.4	110	93	27	2.0	1.643	0.817	<0.1	708	386	0.12	0.2	0.5
16S/1E-23La	6.72	408	99	7.0	21	54	0.06	<1	1.8	34	28	12	3.1	0.893	0.174	<0.1	248	134	<0.05	<0.1	0.4
16S/1E-24N5	8.02	597	136	6.7	35	99	<0.05	3	1.8	56	38	17	3.3	0.012	<0.01	<0.1	383	210	0.05	0.1	0.2
Seaside Basin																					
15S/1E-15N3 (shal)	317	66	6.1	43	13	<0.05	<1	1.2	18	35	5	3.9	<0.01	<0.01	<0.1	208	66	<0.05	0.20	0.1	
15S/1E-15N2 (deep)	1006	267	7.4	146	26	<0.05	<1	1.3	72	107	15	4.5	0.094	0.029	<0.1	600	242	0.11	0.4	0.3	
15S/1E-23Ca (shal)	831	185	7.4	112	46	<0.05	3	1.2	63	74	16	3.8	0.217	0.016	<0.1	494	223	0.07	0.4	0.2	
15S/1E-23Cb (deep)	not sampled in 2015 due to obstruction in well																				
15S/1E-15F1 (shal)	337	71	6.8	44	10	<0.05	1	4.2	20	37	5	2.4	<0.01	<0.01	<0.1	223	71	<0.05	0.2	<0.1	
15S/1E-15F2 (deep)	1148	300	6.0	168	39	<0.05	<1	6.1	86	108	18	4.9	0.048	0.160	<0.1	674	289	0.12	0.4	0.2	
15S/1E-15K5 (shal)	305	63	7.8	46	6	<0.05	2	0.7	16	39	4	2.1	0.065	<0.01	<0.1	214	56	<0.05	0.2	0.10	
15S/1E-15K4 (deep)	628	163	7.5	82	24	<0.05	<1	0.6	43	80	8	3.5	<0.01	<0.01	<0.1	394	---	0.08	0.3	0.3	
15S/1E-11Pa (shal)	360	58	6.1	66	<1	<0.05	<1	182	24	49	3	3.3	0.107	<0.01	<0.1	326	72	0.07	1.5	<0.1	
15S/1E-11Pb (deep)	341	77	6.9	51	4	<0.05	<1	1.6	25	37	4	3.9	5.772	0.051	<0.1	240	79	<0.05	0.2	0.1	
15S/1E-12Fa (shal)	269	52	7.2	44	8	<0.05	1	0.4	13	39	2	2.6	2.017	0.100	<0.1	180	41	0.06	0.2	0.1	
15S/1E-12Fc (deep)	296	57	8.0	45	13	<0.05	2	1.5	19	39	2	2.5	0.970	0.024	<0.1	200	56	0.06	0.2	0.1	

NOTES:

- (1) Maximum contaminant levels are from California Domestic Water Quality and Monitoring Regulations, Title 22, 1977.
- (2) The three values listed for certain constituents refer to the "recommended" level, the "upper" level, and "short-term use" level, respectively.
- (3) The "Practical Quantifiable Limit" for Orthophosphate and Bromide changed in 2012.
- (4) Well 15S/1E-15K4 is being used as a "far-field monitor" for ASR well #4, and as such was sampled for additional constituents in 2015 that are not shown on this table.